WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
# DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 88136
Permit No.
Basin 101

NOTICE OF INTENT NO. 45872

1. OWNER MIKE CASEY (BENNETT)
MAILING ADDRESS 7436 ANNETTE
FALLON, NV 89406

ADDRESS AT WELL LOCATION 7436 ANNETTE

2. LOCATION SW 1/4 NE 1/4 Sec. 20 T 19 N/S R 28 E CHURCHILL County
PERMIT NO. (Issued by Water Resources) 007-122-08 (Parcel No.) VANESSA (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| TOP SOIL | | 0 | 1 | 1 |
| BROWN SAND | | 1 | 20 | 19 |
| BROWN CLAY | | 20 | 22 | 2 |
| BROWN SAND | | 22 | 30 | 8 |
| GREY SAND | | 30 | 60 | 30 |
| BLACK SILT | | 60 | 90 | 30 |
| GREY SAND | | 90 | 95 | 5 |
| GREY CLAY | | 95 | 96 | 1 |
| BROWN SAND | X | 96 | 104 | 8 |

RECEIVED 02 APR 24 PM 12:55 STATE ENGINEER'S OFFICE

Date started 11/25/2001 , 19__
Date completed 2/28/2002 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

| | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|---|
| AIR BLOWN | 30 | | 1 HR |

8. WELL CONSTRUCTION
Depth Drilled 104 Feet Depth Cased 104 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | | To | |
|---|---|---|---|---|---|
| 10 | Inches | 0 | Feet | 50 | Feet |
| 6 5/8 | Inches | 50 | Feet | 104 | Feet |
| | Inches | | Feet | | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 12.9 | .188 | +2 | 104 |

Perforations:
Type perforation MILL SLOT
Size perforation .080
From 98 feet to 102 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50'
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 10'8" feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WELSCO CORP. (Contractor)
Address P. O. BOX 888 (Contractor)
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board ~~772~~ 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2199
Signed (By driller performing actual drilling on-site or contractor)
Date 3/28/2002

USE ADDITIONAL SHEETS IF NECESSARY