WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

23-DCC

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 88185
Permit No.
Basin 093

NOTICE OF INTENT NO. 50415

1. OWNER JASON & NANCY DONDERO
MAILING ADDRESS 1325 Coloman Drive
Reno, Nevada 89403

ADDRESS AT WELL LOCATION
1387 Deer Creek Lane
Reno, Nevada 89506

2. LOCATION SW SE ¼ SE SW ¼ Sec. 23 T. 22N N/S R. 19 E. Washoe County
PERMIT NO. (Issued by Water Resources) 079-470-42 (Parcel No.) Antelope Valley Ranchettes #270 par. 2 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown sandy clays		1	6	5
Brown fine sand		6	54	48
Brown sandy clays		54	87	33
Weathered granite		87	117	30
Fracture	X	117	120	3
Weathered granite		120	153	33
Fracture	X	153	157	4
Weathered granite		157	168	11
Fracture	X	168	176	8
Weathered granite		176	183	7
Fracture	X	183	187	4
Weathered granite		187	200	13

Date started July 31, 2002, 20
Date completed August 6, 2002, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20+		

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
9 7/8 Inches		0 Feet	135 Feet
7 7/8 Inches		135 Feet	200 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	200

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 155 feet to 195 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 feet
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 100 feet below land surface
Artesian flow G.P.M. 20+ P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510

Nevada contractor's license number issued by the State Contractor's Board 0022549
Nevada driller's license number issued by the Division of Water Resources 923 the on-site driller
Signed [signature] By driller performing actual drilling on site or contractor
Date August 21, 2002

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627