WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY
DV-3
PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 88205
Permit No.
Basin 137-B

NOTICE OF INTENT NO. 50936

1. OWNER Round Mountain Gold Corp
MAILING ADDRESS P.O. Box 480, Round Mountain Nevada 89045
ADDRESS AT WELL LOCATION Round Mountain Gold Corporation Pit

2. LOCATION NW ¼ SW ¼ Sec. 19 T. 10 ☒S R. 44 E. Nye County
PERMIT NO. M/01250 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Granite Alluvium		0	450'	450'
North Pod Volcanics		450'	525'	75'
Lake Sediments		525'	630'	105'
Old Volcanics		630'	710'	80'
Tuff		710'	870'	160'
Neat Cement		0	20	20'
⅜ Hole Plug		20	530	510'
Sand Pack		530	820	290'
Cavin Hole		820	870	50'

Date started 7-29-02
Date completed 8-6-02

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
465'	1		5 min.
500'	4		5 min.
600'	5		5 min
700'	6		5 min.
800'	8		5 min.
870'	10		5 min

8. WELL CONSTRUCTION
Depth Drilled 870' Feet Depth Cased 820' Feet

HOLE DIAMETER (BIT SIZE)

		From	To
14"	Inches	0 Feet	20 Feet
6¼"	Inches	20 Feet	525 Feet
6⅛	Inches	525 Feet	870 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8⅝"		¼" Wall	+1.6	20'
1½"		.145 Wall	+1.4	820

Perforations:
Type perforation Vertical Slots
Size perforation .020 Slots
From 530 feet to 820' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 530 feet to 820' feet

9. WATER LEVEL
Static water level 619 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality Clean

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) Eklund Drilling Co.
Address (Contractor) P.O. Box 2748
Elko Nevada 89803
Nevada contractor's license number issued by the State Contractor's Board 0030823
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1786
Signed Craig Dine (By driller performing actual drilling on site or contractor)
Date 8-6-02

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627