

OFFICE USE ONLY
 Log No. 58219
 Permit No. _____
 Basin 137-B

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 50936

1. OWNER ROUND Mtn Gold Corp ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS P.O. BOX 480
ROUND Mtn, NEVADA 89845
 2. LOCATION NW 1/4 SW 1/4 Sec 19 T 10 N S R 44 E N4E County _____
 PERMIT NO. N/A Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>HOLE # DV-6</u>				
<u>ALLUVIUM</u>		<u>0</u>	<u>545</u>	<u>545</u>
<u>CLAY</u>		<u>545</u>	<u>575</u>	<u>30</u>
<u>TUFF</u>		<u>575</u>	<u>860</u>	<u>285</u>
<u>SAND PACK</u>		<u>860</u>	<u>940</u>	<u>320</u>
<u>3/8" HOLE PLUG</u>		<u>540</u>	<u>20</u>	<u>520</u>
<u>Cement</u>		<u>20</u>	<u>0</u>	<u>20</u>

8. WELL CONSTRUCTION
 Depth Drilled 860 Feet Depth Cased 858 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 Inches To 20 Feet
 From 6 1/4 Inches To 5.45 Feet
 From 6 7/8 Inches To 860 Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>N/A</u>	<u>1/4" WALL</u>	<u>2</u>	<u>20</u>
<u>1 1/2</u>	<u>N/A</u>	<u>SCH 40</u>	<u>1.5</u>	<u>858</u>

Perforations:
 Type perforation vertical slot
 Size perforation 1020
 From SCREEN 858 feet to 545 feet
 From BLANK 545 feet to 1.5 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 20
 Placement Method: Pumped Poured
 Cement Grout Concrete Grout
 Gravel Packed: Yes No
 From 860 feet to 540 feet

Date started 7-25 2002
 Date completed 7-29 2002

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>860</u>	<u>10</u>	<u>N/A</u>	<u>1/2 HR</u>

9. WATER LEVEL
 Static water level 400 feet below land surface
 Artesian flow N/A G.P.M. N/A P.S.I.
 Water temperature N/A °F Quality ORANGE

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EKLUND Drilling Co Contractor
 Address P.O. BOX 2748
EIKO, NV 89803 Contractor
 Nevada contractor's license number 0030823
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1942
 Signed William Wiley
 By driller performing actual drilling on site of contractor
 Date 7-29-02