WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

m/o 2002-12

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 88223
Permit No.
Basin 137-B

NOTICE OF INTENT NO. 50933

1. OWNER Round Mtn Gold Corp
MAILING ADDRESS P.O. Box 480
Round Mtn Nevada 89045

ADDRESS AT WELL LOCATION

2. LOCATION SW ¼ NE ¼ Sec. 30 T. 10 N/S R. 44 E. Nye County
PERMIT NO. N/A (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| TUFF | | 0 | 350 | 350 |
| VOLCANICS | | 350 | 1,000 | 650 |
| HOLE # m/o 2002-12 | | | | |
| SAND PACK #8 | | 1000 | 920 | 80 |
| 3/8" HOLEPLUG | | 920 | 20 | 900 |
| CEMENT | | 20 | 0 | 20 |

Date started 6-30 2002
Date completed 8-1 2002

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|---|
| 1000 | 60 | N/A | 1/2 |

8. WELL CONSTRUCTION
Depth Drilled 1000 Feet Depth Cased 1000 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 12 Inches | | 0 Feet | 19 Feet |
| 6 3/4 Inches | | 19 Feet | 645 Feet |
| 6 1/2 Inches | | 645 Feet | 1000 Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 8 5/8 | N/A | 1/4" | +2 | 19 |
| 2" | N/A | Sch-40 | +1.5 | 1000 |

Perforations:
Type perforation ~~.020~~ Vertical Slot
Size perforation .020
From BLANK 1000 feet to 979 feet
From SCREEN 979 feet to 937 feet
From BLANK 937 feet to +1.5 feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 20
Placement Method: ☐ Pumped ☒ Poured

Seal Type:
☐ Neat Cement
☐ Cement Grout
☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 1000 feet to 920 feet

9. WATER LEVEL
Static water level 235 feet below land surface
Artesian flow NO G.P.M. P.S.I.
Water temperature N/A °F Quality Clean

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ellund Drilling Co (Contractor)
Address P.O. Box 2748 (Contractor)
Elko NV 89803
Nevada contractor's license number issued by the State Contractor's Board 0030823
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1942
Signed William Riley
By driller performing actual drilling on site or contractor
Date 8-2-02

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 3-91) (O)-627