WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 88276
Permit No.
Basin 173-A

NOTICE OF INTENT NO. 41654

1. OWNER Twin Springs Ranch
MAILING ADDRESS HC 76 Box 1100
Tonopah NV 89049

ADDRESS AT WELL LOCATION 3 miles East of mile marker # 15 SR 325 in Railroad Valley

2. LOCATION S/W ¼ S/E ¼ Sec. 3 T. 1 N/S R 53 E N/E County

PERMIT NO. 13498 (Issued by Water Resources) 156-35 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☒ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Perforate well waiver # R-420	0 to	50'		
No Log available on this well, Customer said well was 120' TD but depth of well was 124' circulate well with mud tremmie pipe sank to 142' Not sure if well was drilled this deep or just soft sand pumped approximately 29 cubic feet neat cement from bottom up.				

RECEIVED
02 NOV 22 AM 11:03
STATE ENGINEERS OFFICE

Date started 11-4-02, 20
Date complated 11-4-02, 20

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION

Depth Drilled ..... Feet Depth Cased ..... Feet

HOLE DIAMETER (BIT SIZE)

	From	To
..... Inches	..... Feet	..... Feet
..... Inches	..... Feet	..... Feet
..... Inches	..... Feet	..... Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"		.250		

Perforations:
Type perforation mill knife
Size perforation 5/16 x 3"
From 0 feet to 50 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal 142
Placement Method: ☒ Pumped ☐ Poured

Seal Type:
☒ Neat Cement
☐ Cement Grout
☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From ..... feet to ..... feet

9. WATER LEVEL

Static water level 70 feet below land surface
Artesian flow ..... G.P.M. ..... P.S.I.
Water temperature ..... °F Quality .....

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Davis Drilling and Pumps (Contractor)
Address HC 61 Box 54 Hiko NV 89017 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 0028966

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1191

Signed Mike Davis
By driller performing actual drilling on site or contractor

Date 11-4-02

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627