

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
 Log No. 88299
 Permit No. _____
 Basin 090
 NOTICE OF INTENT NO. 48059

1. OWNER US Forest Service ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 870 Emerald Bay Rd
Suite #1, South Lake Tahoe, CA 96150
 2. LOCATION NE 1/4 SW 1/4 Sec. 15 T. 13 N 18 E DOUGLAS County
 PERMIT NO. _____ 1318-15-703-004 Round Hill Subdivision Name
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND		0	3.75'	3.75'
GRAVEL		3.75	5.0	1.25
SAND 20% Coarse Fragm		5.0	6.25	1.25
SAND 50% Coarse Fragm		6.25	7.5	1.25
FINE SAND		7.5	13.8	6.3
Bed Rock		13.8		

RECORDED
 OCT-2 AM 10:59
 STATE ENGINEER'S OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 13.8 Feet Depth Cased 13.8 Feet
 HOLE DIAMETER (BIT SIZE)
 From 7.5 Inches To 13.8 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>		<u>PVC</u>	<u>+1</u>	<u>-13.8'</u>

 Perforations:
 Type perforation machine cut slots
 Size perforation 0.010
 From 8.5 feet to 13.8 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 5' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 6.8 feet to 13.8' feet


Date started Sept 17, 2002
 Date completed Sept 17, 2002

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

9. WATER LEVEL
 Static water level 12.5' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name _____ Contractor _____
 Address _____ Contractor _____
 Nevada contractor's license number issued by the State Contractor's Board _____
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2200
 Signed Judd Mahone
 By driller performing actual drilling on site or contractor
 Date 09/27/02



Devaux Lane

75 ft. →

75 ft. →

⊕ Well Locations

US 50

100 0 100 200 Meters

Round Hill