WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 28539
Permit No.
Basin 101

NOTICE OF INTENT NO. 50595

1. OWNER Frank Woolsey
MAILING ADDRESS 2161 W Williams Ave PMB 280
Fallon, NV 89406

ADDRESS AT WELL LOCATION 1125 Robin Drive,
Fallon, NV 89406

2. LOCATION NW 1/4 SE 1/4 Sec. 21 T 19N N/S R 28E E churchill County
PERMIT NO. (Issued by Water Resources) 008-282-30 (Parcel No.) Hawk Properties (Subdivision Name)

3. **WORK PERFORMED**
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. **PROPOSED USE**
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. **WELL TYPE**
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thickness
Brown Sand		0	9	9
Brown Clay		9	19	10
Brown Sand		19	28	9
Brown Clay		28	31	3
Gray Clay		31	35	4
Brown Clay		35	37	2
Black CLay		37	40	3
Gray Sand		40	50	10
Gray Clay		50	56	6
Brown Sand	XX	56	58	2

RECEIVED
02 JUL -1 PM 12:59
STATE ENGINEER'S OFFICE

Date started 06/07/2002, 19__
Date completed 06/07/2002, 19__

7. **WELL TEST DATA**
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		1HR

8. **WELL CONSTRUCTION**
Depth Drilled 58 Feet Depth Cased 58 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	58	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 PVC	3.92	.258	10	58
6 5/8	12.92	.188	0	10

Perforations:
Type perforation Saw Cut
Size perforation 1/8
From 55 feet to 58 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 55 feet to 58 feet

9. **WATER LEVEL**
Static water level 16 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. **DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1264 (Contractor)
Fallon Nv. 89407
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2212
Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 06/10/2002

USE ADDITIONAL SHEETS IF NECESSARY