

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 88345
 Permit No. _____
 Basin. 102

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 46311

1. OWNER Vivian Simmons ADDRESS AT WELL LOCATION 7095 Annetta Silver Spring Lyon
 MAILING ADDRESS _____
 2. LOCATION NW 1/4 NW 1/4 Sec. 13 T. 17 N/S R. 24 E. County _____
 PERMIT NO. 17-231-62 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>DIRT-ROCK</u>		<u>0</u>	<u>8</u>	<u>8</u>
<u>BLACK ROCK</u>		<u>8</u>	<u>80</u>	<u>72</u>
<u>FRACTURED ROCK</u>		<u>80</u>	<u>121</u>	<u>41</u>
<u>GRAY-BLACK CLAY</u>		<u>121</u>	<u>125</u>	<u>4</u>
<u>GREENISH GRAY ROCK</u>		<u>125</u>	<u>155</u>	<u>30</u>
<u>BLACK-GREEN ROCK</u>		<u>155</u>	<u>216</u>	<u>61</u>
<u>GRAY CLAY-BLACK ROCK</u>		<u>216</u>	<u>263</u>	<u>57</u>
<u>BLACK GRAVEL</u>		<u>263</u>	<u>295</u>	<u>32</u>

8. WELL CONSTRUCTION
 Depth Drilled 295 Feet Depth Cased 295 Feet
 HOLE DIAMETER (BIT SIZE)
 From 9 7/8 Inches To 0 Feet 295 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>14</u>	<u>.188</u>	<u>+1</u>	<u>295</u>

Perforations:
 Type perforation Factory milled - Touch cut
 Size perforation 3/32" x 3"
 From 255 feet to 295 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: _____
 Depth of Seal 52 ft Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 52 feet to 295 feet

9. WATER LEVEL
 Static water level 190 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality CLEAR

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Blain Drilling & Pump Co.
P.O. Box 1255
 Address Carson City NV 89702
 Nevada contractor's license number issued by the State Contractor's Board 46498
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2167
 Signed Jack D. Tom
 By driller performing actual drilling on site or contractor
 Date 7/1/02

Date started June 27 02
 Date completed June 28 02

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>15</u>		<u>1.5</u>

RECEIVED
 02 JUL 18 AM 11:40
 STATE ENGINEERS OFFICE