WASHOE # 020193

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

office use only
Log No. 88369
Permit No.
Basin 084

NOTICE OF INTENT NO 49906

1. OWNER MAILING ADDRESS: **Amy DeLaCruz & Steve Handa**, **6005 Greyvan Rd.**, **Sparks, NV 89436**

ADDRESS AT WELL LOCATION: **6005 Greyvan Rd. Sparks**

2. Location: **SE** 1/4 **NE** 1/4 Sec **36** T **23N** R **20E** **Washoe** County

PERMIT NO. PARCEL NO. **076-110-27** SUBDIVISION NAME

3. WORK PERFORMED
X New Well | Replace | Recondition
Deepen | Abandon | Other

4. PROPOSED USE
X Domestic | Irrigation | Test
Municipal/Industrial | Monitor | Stock

5. WELL TYPE
Cable | X Rotary | RVC
X Air | Other | X Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	100	100
				0
Clay		100	140	40
				0
Gravel & Sand		140	175	35
				0
Clay		175	225	50
				0
Clay & Gravel		225	245	20
				0
Granite		245	350	105
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0

8. WELL CONSTRUCTION
Depth Drilled **350** feet Depth Cased **350** feet

HOLE DIAMETER (BIT SIZE)

		From	To
11	inches	**0** feet	**270** feet
6 1/8	inches	**270** feet	**350** feet
	inches	feet	feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To Feet
6 5/8	**12.94**	**188**	**+1 1/2**	**270**
5	**6.96**	**188**	**250**	**350**

Perforations::
Type Perforation **Factory**
Size perforation **3/32 x 3"**
From **230** feet to **270** feet
From **290** feet to **350** feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal **X** YES No
Depth of Seal **50** feet
x Pumped
Poured

Seal Type:
Neat Cement
x Cement Grout
Concrete Grout

Gravel Packed: **X** Yes No
From **50** feet to **270** feet

9 WATER LEVEL
Static water level **55** feet below land surface
Artesian flow **0** GPM **0** P.S.I.
Water Temperature **cold** Degrees F Quality **clear**

Date started **9-30** -02
Date completed **10-14** -02

7. WELL TEST DATA
TEST METHOD: Bailer Pump **x** Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (hours)
30	195	.30 min.
50	**245**	**.30 min.**
60	295	.30 min.

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **McKay Drilling, Inc.**
2290 Pioneer Drive
Reno, NV 89509
NV Contractors No. **14170**
NV Driller's Lic (on site) **1878**

Signed
By driller performing actual drilling on site or contractor

Date 10-16 -02