

OFFICE USE ONLY  
 Log No. 88489  
 Permit No. \_\_\_\_\_  
 Basin. 137-

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 50932

1. OWNER ROUND MTN Gold Corporation ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS P.O. Box 480  
ROUND MTN, NEVADA 89015  
 2. LOCATION SW 1/4 NW 1/4 Sec 30 T. 10 N R. 44 E N4E County \_\_\_\_\_  
 PERMIT NO. N/A Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>ALLUVIUM</u>		<u>0</u>	<u>200</u>	<u>200</u>
<u>VOLCANICS</u>		<u>200</u>	<u>1000</u>	<u>800</u>
<u>SAND PACK #8</u>		<u>1000</u>	<u>700</u>	<u>300</u>
<u>NATIVE FILL</u>		<u>700</u>	<u>150</u>	<u>550</u>
<u>1/8" Hole PLOG</u>		<u>150</u>	<u>15</u>	<u>135</u>
<u>Cement</u>		<u>15</u>	<u>0</u>	<u>15</u>

8. WELL CONSTRUCTION  
 Depth Drilled 1000 Feet Depth Cased 1000 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 0 To 20  
12 Inches. 20 Feet. 1000 Feet  
6 3/4 Inches. \_\_\_\_\_ Feet. \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches. \_\_\_\_\_ Feet. \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2 3/8"</u>	<u>N/A</u>	<u>sch 40</u>	<u>1000</u>	<u>715</u>

Perforations:  
 Type perforation Vertical slot  
 Size perforation .020  
 From BLANK 1000 feet to 979 feet  
 From SCREEN 979 feet to 938 feet  
 From BLANK 938 feet to 715 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 715  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 1000 feet to 700 feet

9. WATER LEVEL  
 Static water level 525 feet below land surface  
 Artesian flow N/A G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature N/A °F Quality Clear

Date started 6-6 2002  
 Date completed 6-13-02 2002

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>3</u>	<u>N/A</u>	<u>1/2 hr</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name EKLUND Drilling Co Contractor  
 Address P.O. Box 2748 Contractor  
EIKO NV 89803  
 Nevada contractor's license number 0030823  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1942  
 Signed William Riley  
 By driller performing actual drilling on site or contractor  
 Date 6-15-02