

OFFICE USE ONLY
 Log No. 88337
 Permit No. _____
 Basin 105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 50899

1. OWNER Steve Maricola ADDRESS AT WELL LOCATION 1682 Hyde St Minden NV 89423
 MAILING ADDRESS 1682 Hyde St Minden NV 89423
 2. LOCATION NE 1/4 NW 1/4 Sec 2 T 13 N S R 20 E Douglas County
 PERMIT NO. Waiver Ltr. 1320 02 001 095 Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay		225	260	35
SAND LAYERS WITH CLAY LAYERS		260	340	80
Clay		340	440	100
SAND + Gravel		440	500	60

8. WELL CONSTRUCTION
 Depth Drilled 500 Feet Depth Cased 318 Feet
 HOLE DIAMETER (BIT SIZE)
 From 7 7/8 Inches 225 Feet 500 Feet
 To _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>.188</u>	<u>28</u>	<u>98</u>
<u>6 3/8</u>		<u>.188</u>	<u>158</u>	<u>258</u>

Perforations:
 Type perforation factory slot
 Size perforation 1/16 x 3"
 From 98 feet to 158 feet
 From 258 feet to 318 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 201 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 60.0 °F Quality _____

Date started 6-28-02
 Date completed 7-3-02

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>25+</u>		<u>2 hours</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Sierra Nevada Drilling & Pumping Contractor
 Address 3540 Incline Drive Contractor
Cedar City, NV 89705
 Nevada contractor's license number 52078
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1902
 Division of Water Resources, the on site driller
 Signed John B. Smith
 By driller performing actual drilling on site or contractor
 Date 7/8/02