WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 88557
Permit No.
Basin 179

NOTICE OF INTENT NO. 45804

1. OWNER Lois Chalmers
MAILING ADDRESS 4122 Tennyson Street
San Diego, California 92107

ADDRESS AT WELL LOCATION Approximately 5 miles SE of Ely

2. LOCATION SW ¼ SW ¼ Sec. 7 T. 15 N/S R. 64 E White Pine County
PERMIT NO. Lot 12 (Issued by Water Resources) APN 12-780-09 (Parcel No.) Ward Mountain (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	2	2
Sand & Gravel		2	15	13
Course Gravel		15	20	5
Sand & Gravel		20	55	35
Clay & Course Gravel		55	65	10
Clay		65	80	15
Sand & Gravel		80	105	25
Clay & Gravel		105	125	20
Course Gravel	X	125	130	5
Brown Clay		130	200	70
Clay with water bearing	X	200		
Sand & Gravel Stringers			220	20
Brown Clay		220	262	42

Date started September 2, 2002
Date completed September 6, 2002

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	80	2
30	90	2

8. WELL CONSTRUCTION
Depth Drilled 262 Feet Depth Cased 262 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
10	0	262

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	12.92	.188	0	262

Perforations:
Type perforation Factory
Size perforation 1/8" X 2" 6 Rows
From 80 feet to 161 feet
From 180 feet to 241 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50 Feet
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout
Gravel Packed: [X] Yes [ ] No
From 50 feet to 262 feet

9. WATER LEVEL
Static water level 130 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Christiansen Drilling, Inc. (Contractor)
Address 557 Ely Avenue (Contractor)
Ely, Nevada 89301
Nevada contractor's license number issued by the State Contractor's Board 14790
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1793
Signed Rich Lewis By Jerold D. Christiansen (By driller performing actual drilling on site or contractor)
Date September 12, 2002

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627