

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 48343

1. OWNER Alan Hattie Rose ADDRESS AT WELL LOCATION _____
MAILING ADDRESS 1505 DAVENPORT Menden, NV 89423 ADDRESS 1738 TWIN BELLS LN Menden, NV 89423
2. LOCATION SW 1/4 SE 1/4 Sec. 14 T. 13 N/S R. 20 E Douglas County
PERMIT NO. 133014002-014 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED New Well Replace Recondition Deepen Abandon Other _____
4. PROPOSED USE Domestic Irrigation Test Municipal/Industrial Monitor Stock
5. WELL TYPE Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND + D.C.		0	4	4
BROWN CLAY		4	7	3
SAND + GRAVEL		7	30	23
BROWN CLAY		30	38	8
FRONT SAND		38	52	14
FRONT CLAY		52	60	8
FRONT SAND + ROCK		60	105	45
FRONT SAND + CLAY		105	130	25
FRONT SAND + CLAY + ROCK		130	200	70
SAND + ROCK				

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet
HOLE DIAMETER (BIT SIZE)
12 1/2 Inches From 0 Feet To 200 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 1/2</u> "		<u>155</u> "	<u>0</u>	<u>200</u>

Perforations:
Type perforation FACTORY
Size perforation _____
From 150 feet to 200 feet
From 100 feet to 150 feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
Depth of Seal 30
Placement Method: Pumped Poured
Gravel Packed: Yes No
From 200 feet to 50 feet

9. WATER LEVEL
Static water level 30 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature 61.1 °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name **NEVADA PUMP & DRILLING**
Address **P.O. BOX 2227 DAYTON, NV 89403**
Nevada contractor's license number issued by the State Contractor's Board _____
Nevada driller's license number issued by the Division of Water Resources, the on-site driller _____
Signed Thomas S. ...
By driller performing actual drilling on site or contractor
Date 7-15-22

Date started JUNE 29, 2022
Date completed JUNE 30, 2022

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>30</u>		<u>1</u>