WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 88560
Permit No.
Basin 105

NOTICE OF INTENT NO. 50346

1. OWNER Larry Fletcher
MAILING ADDRESS PO Box 2879
Gardnerville, NV 89410

ADDRESS AT WELL LOCATION 1812 Long Ct
Gardnerville, NV 89410

2. LOCATION NW¼ SW¼ Sec. 24 T. 12 N/S R. 20 E/W Douglas County
PERMIT NO. (Issued by Water Resources) 1220 24 302 001 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sand + Rock		0	5	5
Brown Clay		5	7	2
Sand + Boulders		7	80	73
Brown Clay + Rock		80	90	10
Pink Clay + Rock		90	110	20
Brown, Red, Green		110	160	40
Black, Grey Rock				

RECEIVED 2002 AUG 8 AM 11:37 WATER RESOURCES OFFICE

Date started 8-17-02, 2002
Date completed 8-23-02, 2002

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15		2

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)
10 5/8 Inches From 0 Feet To 160 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16 5/8		.188	0	160

Perforations:
Type perforation FACTORY
Size perforation
From 120 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50'
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 160 feet to 50 feet

9. WATER LEVEL
Static water level 85 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Nevada Pump + Drilling (Contractor)
Address PO Box 2227 (Contractor)
Dayton, NV 89403
Nevada contractor's license number issued by the State Contractor's Board 0046357
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2187
Signed Thomas Evans (By driller performing actual drilling on site or contractor)
Date Aug. 1, 2002

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627