



Log No. 88561  
 Exam No. \_\_\_\_\_  
 Basin Q85

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 50426

1. OWNER BYRON WHOLEY ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 10270 Crockett 250 Aqua Fria Drive  
Reno, Nevada 89506 Sparks, Nevada 89436  
 2. LOCATION SW  $\frac{1}{4}$  SE  $\frac{1}{4}$  Sec. 19 T. 21N N/S R. 21 E. Washoe County  
 PERMIT NO. 076-371-42 Spanish Springs  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	1	1
Brown clay with boulders & gravel		1	6	5
Cemented gravels		6	7	1
Brown sandy clays		7	35	28
Yellow sandy clays		35	46	11
Rusty brownsandy clays		46	85	39
Brown sandy clays		85	221	136
Brown volcanic rocks		221	251	30
Fractured volcanic rock (NO WATER)		251	255	4
Brown volcanic rock		255	290	35
Fractured volcanic rock	X	290	295	5
Brown volcanic rock		295	318	23
Fractured volcanic rock	X	318	330	12
Brown volcanic rock		330	335	5
Fractured volcanic rock	X	335	337	2
Brown volcanic rock		337	346	9
Fractured volcanic rock		346	353	7

8. WELL CONSTRUCTION  
 Depth Drilled 353 Feet Depth Cased 353 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 0 Feet 50 Feet  
8 5/8 Inches 50 Feet 353 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	353

Perforations:  
 Type perforation factory sawed slot  
 Size perforation 3/32 x 3 x 5 around  
 From 287 feet to 347 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50 feet  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 353 feet

9. WATER LEVEL  
 Static water level 250 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 25 P.S.I.  
 Water temperature cold °F Quality clear

Date started October 15, 2002, 20 \_\_\_\_  
 Date completed October 18, 2002, 20 \_\_\_\_

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
25			

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name WAYNE DRILLING, INC. Contractor  
 Address P.O. BOX 12370 Contractor  
RENO, NEVADA 89510  
 Nevada contractor's license number issued by the State Contractor's Board 0022549  
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 923  
 Signed Wayne Drilling, Inc. By driller performing actual drilling on site or contractor  
 Date October 21, 2002