WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 88567
Permit No.
Basin 1076

NOTICE OF INTENT NO. 41457

1. OWNER Amec. Eng. Sparks NV
MAILING ADDRESS
ADDRESS AT WELL LOCATION 485 Truck Inn Fernley NV 89408

2. LOCATION SE ¼ NW ¼ Sec. 7 T. 20 N/S R. 25 E. Lyon County
PERMIT NO. 0/0 m/o #5 (Issued by Water Resources) 21-221-05 (Parcel No.) 1126, 1182, 2000, 1200 (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG MW1

Material	Water Strata	From	To	Thickness
Well was in good				
Condition After I				
Took off well				
Cap Then I				
put my Rods				
Down The Caseing				
Broke out Bottom				
Cap Then Trimmy				
grout from				
The Bottom to				
Surface				

RECEIVED
JUL 18 PM 12:17
STATE ENGINEERS OFFICE

Date started 4/29/02, 19
Date completed 4/30/02, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
N/A		

8. WELL CONSTRUCTION
Depth Drilled 75.5 Feet Depth Cased 75.5 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	75.5 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4	Factory	020	0	75.5

Perforations:
Type perforation Factory
Size perforation 0.010
From 55 feet to 75.5 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal Surface 75.5
Placement Method: ☒ Pumped ~~☒ Poured~~
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 64.98 feet below land surface
Artesian flow n/a G.P.M. N/A P.S.I.
Water temperature cold °F Quality n/a

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Andresen Exploration Drilling (Contractor)
Address 1635 Belford Rd Reno NV 89509 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 34525
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M/2139
Signed [signature] By driller performing actual drilling on site or contractor
Date 5/09/02

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627