

no 6

WHITE-DIVISION OF WATER RESOURCES  
CANARY-CLIENT'S COPY  
PINK-WELL DRILLER'S COPY

STATE OF NEVADA  
DIVISION OF WATER RESOURCES

OFFICE USE ONLY

Log No. 850317

Permit No. 087

Resin. 087

NOTICE OF INTENT NO 46038

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Kerry Lyman ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS One E. First St Suite 800 119 E 4th St  
Reno NV 89505 Reno NV 89505  
 2. LOCATION SW 1/4 NE 1/4 Sec 11 T. 19 N. R. 19 E. Washoe County  
 PERMIT NO. WL 030008 007-298-06 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock

5. WELL TYPE  Cable  Rotary  RVC  Air  Other Septic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Gravelly clay</u>		<u>0</u>	<u>17</u>	
<u>Ben</u>				
<u>Gravelly sand</u>		<u>17</u>	<u>19</u>	
<u>Silty gravel</u>		<u>19</u>	<u>27</u>	
<u>Ben</u>				
<u>Cobbles</u>				
<u>Clayey gravels</u>	<u>27'</u>	<u>27</u>	<u>32</u>	
<u>wet some cobbles</u>				
<u>Silty gravels</u>		<u>32</u>	<u>37</u>	
<u>Cobbles</u>				

8. WELL CONSTRUCTION

Depth Drilled 37 Feet Depth Cased 37 Feet

HOLE DIAMETER (BIT SIZE)

From 6 Inches To 37 Feet

Inches Feet Feet

Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>		<u>Sch 40</u>	<u>0</u>	<u>22</u>

Perforations:

Type perforation Factory

Size perforation .020

From 22 feet to 37 feet

From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  Cement Grout  Concrete Grout

Depth of Seal 30

Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No

From 20 feet to 37 feet

RECEIVED  
OFFICE - 7 NOV 03  
STATE ENGINEERING OFFICE

Date started 1-22, 2003  
 Date completed 1-22, 2003

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL

Static water level 27 feet below land surface

Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.

Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Boart Longyear Contractor

Address P.O. Box 1000 Contractor

Dayton NV 89403

Nevada contractor's license number issued by the State Contractor's Board 0010157

Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2222

Signed Bruce Anderson By driller performing actual drilling on site or contractor

Date 1-22-03