WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 88648
Permit No.
Basin Ø76

NOTICE OF INTENT NO. 44842

1. OWNER town of Fernley
MAILING ADDRESS

ADDRESS AT WELL LOCATION

2. LOCATION SE 1/4 SW 1/4 Sec. 1 T 20 N/S R 24 E Washoe County
PERMIT NO. MO. 1223 (Issued by Water Resources) 84-230-02 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☑ Other expl.

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	75	75
Sand w/clay		75	275	200
Gravel Sand & Clay		275	325	50
Sand		325	375	50
Sandy Clay		375	395	20
Gravel Sand & Clay		395	475	80
Sand		475	550	75
Hard rock		550	560	10
Gravel sand & clay		550	675	125
Fine gravel & sand		675	700	25
Medium gravel & sand		700	825	125
Sand & clay		825	850	25
Fine to medium Gravel sand & clay		850	1075	225

RECEIVED
02 DEC 31 AM 10:47
STATE ENGINEERS OFFICE

Date started 9-15, 1901
Date completed 10-13, 1901

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☑ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
180	<3'	24

8. WELL CONSTRUCTION
Depth Drilled 1075 Feet Depth Cased 1000 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12¼ Inches	0 Feet	1000 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6⅝	18.2	.250	+1	1000

Perforations:
Type perforation mill slot + screen.
Size perforation .0080
From 250 feet to 270 feet
From 350 feet to 370 feet
From 500 feet to 520 feet
From 605 feet to 625 (screen) feet
From 750 feet to 775 (screen) feet
950 970 (screen)

Surface Seal: ☑ Yes ☐ No
Depth of Seal 100
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 100 feet to 1000 feet

9. WATER LEVEL
Static water level 104-6 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name [signature] Contractor
Address Box 888 Contractor
Fallon Nv. 89406.
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 772
Signed [signature] by driller performing actual drilling on-site or contractor
Date Nov-17-01

USE ADDITIONAL SHEETS IF NECESSARY