

mw-3

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY

Log No. 88650
 Permit No. 087
 Basin 087

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 46036

1. OWNER Kerry Lyman ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS One East First Str Suite 800 103 North Center Str
Reno NV 89505 Reno NV 89505
 2. LOCATION SW 1/4 NE 1/4 Sec 11 T 19 R 19 Washoe County
 PERMIT NO. W 030008 Issued by Water Resources Parcel No. 007-298-13 Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Sonic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Gravelly Clay Dark Brn</u>		<u>0</u>	<u>5</u>	<u>5</u>
<u>Sandy clay</u>		<u>5</u>	<u>10</u>	<u>5</u>
<u>Sandy gravels</u>		<u>10</u>	<u>15</u>	<u>5</u>
<u>Sandy clay gravels</u>		<u>15</u>	<u>25</u>	<u>10</u>
<u>Silty gravels cobbles</u>		<u>25</u>	<u>37</u>	<u>12</u>

8. WELL CONSTRUCTION
 Depth Drilled 37 Feet Depth Cased 37 Feet

HOLE DIAMETER (BIT SIZE)
 From 6 Inches To 37 Feet
 _____ Inches _____ Feet
 _____ Inches _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2"</u>		<u>Sch 40</u>	<u>0</u>	<u>21</u>

Perforations:
 Type perforation Factory
 Size perforation .020
 From 21 feet to 36 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 19
 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 19 feet to 37 feet

RECEIVED
13 JUN 13 04 AM 10:57
STATE ENGINEERS OFFICE

Date started 1-21, 2003
 Date completed 1-21, 2003

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL
 Static water level 28 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Boart Longyear Contractor
 Address PO Box 1000 Contractor
Dayton NV 89403
 Nevada contractor's license number issued by the State Contractor's Board 0010157
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M 2222
 Signed Bruce Anderson
 By driller performing actual drilling on site or contractor
 Date 1-21-03