



OFFICE USE ONLY
 Log No. 388056
 Permit No. 107
 Basin. 107
 NOTICE OF INTENT NO. 19385

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Kirka Const ADDRESS AT WELL LOCATION 45 Lower Colony Rd
 MAILING ADDRESS WELLINGTON, NV
 2. LOCATION NW 1/4 SE 1/4 Sec 34 T 11 N/S R. 23 E County Lyon
 PERMIT NO. 10-36-14 Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND		0	12	12
LARGE GRAVEL-SAND		12	30	18
STREAKY CLAY-GRAVEL		30	145	115
FINE SANDY GRAVEL	X	145	162	17
MEDIUM GRAVEL-CLAY	X	162	200	38

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 300 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>14</u>	<u>.188</u>	<u>+1</u>	<u>200</u>

Perforations:
 Type perforation Factory milled
 Size perforation 3/32" X 3/32"
 From 180 feet to 200 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 ft Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 200 feet

9. WATER LEVEL
 Static water level 86 feet below land surface
 Artesian flow _____ G.P.M. P.S.I.
 Water temperature WARM °F Quality CLOUDY (yellow)

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Blain Drilling & Pump Co.
 Address P.O. Box 1255
Carson City, NV 89702

Nevada contractor's license number issued by the State Contractor's Board 46498
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2167
 Signed Jack Nelson
 By driller performing actual drilling on site or contractor
 Date _____

7. WELL TEST DATA
 TEST METHOD: Bailer Pump Air Lift
 G.P.M. 15-18 Draw Down (Feet Below Static) _____ Time (Hours) 1.5

RECEIVED
 JAN 22 PM 2:38
 ENGINEERS OFFICE

Date started 15-JAN 2003
 Date completed 17-JAN 2003