WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

P8-2

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 88692
Permit No.
Basin 0605

NOTICE OF INTENT NO. 51118

1. OWNER Newmont Mining
MAILING ADDRESS PO Box 3887
Valmy, Nv. 89438
ADDRESS AT WELL LOCATION Lone Tree

2. LOCATION SW ¼ NW ¼ Sec. 23 T. 34 N/S R. 42 E. Humbolt County
PERMIT NO. (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☑ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
dump material	none	0	117	
Top Soil (original ground level)		117	120	
6" monument 5 feet tall				

8. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 117 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 Inches	0 Feet	120 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2		Sch 80	+4	117

Perforations:
Type perforation slot
Size perforation .020
From 107 feet to 117 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 5 feet
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 10 feet to 118 feet

9. WATER LEVEL
Static water level none feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eklund Drilling, Co.
Address PO Box 2748 (Contractor)
Elko, Nv. 89803 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0030823
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M 1880
Signed (By driller performing actual drilling on site or contractor)
Date 1-9-03

Date started 12-12-2002
Date completed 12-12-2002

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
no water		

RECEIVED 03 JAN 16 AM 11:18 STATE ENGINEER'S OFFICE

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627