WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 88731
Permit No.
Basin 087

NOTICE OF INTENT NO. 47890

1. OWNER Rick LaMay
MAILING ADDRESS P.O. Box 11365
Reno, NV 89510

ADDRESS AT WELL LOCATION 465 W. Ranger Dr.

2. LOCATION NW 1/4 SW 1/4 Sec. 23 T 20N N/S R 19E E Washoe County
PERMIT NO. R-429 Issued by Water Resources
082-451-07 Parcel No.
Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
On this date we abandoned the 6 5/8" x 103' well. We first tried to perforate the well, but due to scaling in the well, we were unable to get the perforator down past 5'. We called Tim Hunt and received a waiver for perforating the casing. We then pumped approximately 1 1/2 yards of neat cement mixed 5.2 gallons of water per sack and pumped from the bottom to the top. The well was inside of a pump house.				
Washoe County Permit #WL020142				

RECEIVED 03 JAN 22 AM 10:54 STATE ENGINEER'S OFFICE

Date started 1/9/2003 , 19__
Date completed 1/10/2003 , 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased 103 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	0	103

Perforations:
Type perforation not known.
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal 100 ft.
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 3' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. Contractor
Address 1600 Mt. Rose Hwy Contractor
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719
Signed R. Bruce MacKay
By driller performing actual drilling on-site or contractor
Date 1/10/03

USE ADDITIONAL SHEETS IF NECESSARY