



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 47934

1. OWNER Donna Martin ADDRESS AT WELL LOCATION 505 Appaloosa Cir Reno NV 89506  
 MAILING ADDRESS 305 Appaloosa Cir Reno NV 89506  
 2. LOCATION SE 1/4 SE 1/4 Sec 5 T 23 S R 18 E Washoe County Washoe  
 PERMIT NO. 078-221-21 Parcel No. 078-221-21 Subdivision Name Rancho Harwin

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Mvd

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	38	38
Clay		38	54	16
Clay Hard		54	128	74
Sandy Clay		128	140	12
Rock (Track)		140	165	25
Rock		165	255	90
Sand & Clay layers		255	400	145

8. WELL CONSTRUCTION  
 Depth Drilled 400 Feet Depth Cased 400 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 11 Inches To 0 Feet 400 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>12.9</u>	<u>.188</u>	<u>2+</u>	<u>400</u>

Perforations:  
 Type perforation Saw slot  
 Size perforation  
 From 140 feet to 160 feet  
 From 260 feet to 290 feet  
 From 300 feet to 320 feet  
 From 340 feet to 360 feet  
 From 380 feet to 400 feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 30  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 30 feet to 400 feet

9. WATER LEVEL  
 Static water level 150 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 12/3/02  
 Date completed 12/20/02

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>15</u>	<u>6.5</u>	<u>6.5</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Olenki Drilling and Pump Co. Contractor  
 Address 15045 Red Rock Rd Reno NV 89506 Contractor  
 Nevada contractor's license number 50343 issued by the State Contractor's Board.  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1656  
 Signed John F Olenki  
 By driller performing actual drilling on site or contractor  
 Date 12/20/02

RECEIVED  
 02 DEC 26 AM 10:47  
 STATE ENGINEERS OFFICE