

OFFICE USE ONLY
 Log No. 88739
 Permit No. _____
 Basin 108
 NOTICE OF INTENT NO. 47907

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Dary Harder ADDRESS AT WELL LOCATION No address at this time
 MAILING ADDRESS 1248 Highway 208 Yerington Nev. 89447
 2. LOCATION NW 1/4 NE 1/4 Sec 3 T 11 N/S R 25 E County _____
 PERMIT NO. 12-401-11 Issued by Water Resources Parcel No. _____ Subdivision Name None

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sandy loam top soil</u>		<u>0</u>	<u>5</u>	<u>5</u>
<u>Big boulders</u>		<u>5</u>	<u>22</u>	<u>17</u>
<u>Brown Clay</u>		<u>22</u>	<u>37</u>	<u>15</u>
<u>Gravel + sand yes</u>		<u>37</u>	<u>75</u>	<u>38</u>
<u>Gravel + sand with some large rock yes</u>		<u>75</u>	<u>130</u>	<u>55</u>

8. WELL CONSTRUCTION
 Depth Drilled 130 Feet Depth Cased 130 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
12 Inches 0 Feet 100 Feet
9 Inches 100 Feet 130 Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 7/8</u>		<u>1 8/8</u>	<u>0</u>	<u>130</u>

 Perforations:
 Type perforation Factory saw slat
 Size perforation 3/32 x 3
 From 100 feet to 130 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 100 ft Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

RECEIVED
 08 JAN - 8 AM 11:06
 STATE ENGINEERS OFFICE

Date started Nov 27 - 02
 Date completed Dec 2 - 02

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30</u>	<u>0</u>	<u>5 hrs</u>

9. WATER LEVEL
 Static water level 25 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold F Quality good
 10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Edmund Miller Contractor
 Address P.O. 92 Smith Pl. 89430 Contractor
 Nevada contractor's license number 32166 A issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 718
 Signed Edmund Miller
 By driller performing actual drilling on site or contractor
 Date Jan 6 - 03