WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 88769
Permit No.
Basin: 087

NOTICE OF INTENT NO. 44112

1. OWNER Washoe County Dept of Water Resources Utility Services Division
MAILING ADDRESS P.O. Box 11130
Reno Nevada 89520-0027
ADDRESS AT WELL LOCATION 12500 Mira Loma Road

2. LOCATION NW ¼ SE ¼ Sec. 15 T. 18 N/S R. 20 E. Washoe County
PERMIT NO. (Issued by Water Resources) 140-020-01 Parcel No. Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. N/A PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. N/A WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. MW#3 LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
I drilled around the 4" pvc's steel monument casing. When I pulled the steel monument casing it broke off about 3' below surface.				
I pulled the 4" pvc and snapped it 10' below surface. The remaining 20' of 4" .020 slotted pvc was filled with neat cement to the surface. 6 bags were used.				
Bottom cap broken before filling.				
Pulled 10 feet of blank and the start of .020 slotted pvc.				

Date started 10/21/02, 2002
Date completed 10/21/02, 2002

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. N/A WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation
Size perforation
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 29'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 8' feet below land surface
Artesian flow No G.P.M. ____ P.S.I.
Water temperature Warm °F Quality Murky

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Dale A Lehman (Contractor)
Address 520 Edison Way (Contractor)
Reno NV 89502
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1976
Signed Dale A. Lehman (By driller performing actual drilling on site or contractor)
Date 10/22/02

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627