



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Washoe County DWR ADDRESS AT WELL LOCATION 1226 Westfield Reno Nev
 MAILING ADDRESS 4930 Energy Way Reno Nev

2. LOCATION SE 1/4 NE 1/4 Sec. 15 T. 19 N. R. 19 E. Washoe County
 PERMIT NO. NAC 30140 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition Domestic Irrigation Test Cable Rotary RVC
 Deepen Abandon Other..... Municipal/Industrial Monitor Stock Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Reveal Bore		0	12	12
Sand Gravel Cobbles		12	6	43
Clay + Cobbles		6	9	3
Sand Gravel Cobbles		9	19	10
Clay + Cobbles		19	20	1
Sand Gravel Cobbles		20	23	3
Silty Sand		23	25	2
Sand	Yes	25	25.5	0.5
Clay + Cobbles		25.5	26	0.5
Silty Sand		26	28	2
Clean Sand	Yes	28	30	2
Sandy S.I.T		30	32	2
Clay		32	40	8
Sealed well brick to 31' with bentonite clay				

8. WELL CONSTRUCTION
 Depth Drilled 40 Feet Depth Cased 31 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 To 40
6 Inches 0 Feet 40 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2		3/4	0	31

Perforations:
 Type perforation Slotted
 Size perforation 2"
 From 16 feet to 31 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement Cement Grout
 Depth of Seal 14 Concrete Grout
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 14 feet to 31 feet

9. WATER LEVEL
 Static water level 24 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Prosonic Corp Contractor
 Address 305 E Cornstock Contractor
Chandler 172
 Nevada contractor's license number issued by the State Contractor's Board 0051965
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1677
 Signed J.J. Chandler
 By driller performing actual drilling on site or contractor
 Date 3/18/03

Date started 3/18 2003
 Date completed 3/18 2003

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)