WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 88880
Permit No.
Basin 061

NOTICE OF INTENT NO. 48568

1. OWNER Barrick Goldstrike Mines PZ99-11
MAILING ADDRESS P.O. Box 29
Elko, NV 89803

ADDRESS AT WELL LOCATION Barrick Goldstrike minesite, north of Carlin, NV.

2. LOCATION NE 1/4 NE 1/4 Sec. 25 T 36N N/S R 49E E Eureka County
PERMIT NO. N/A (Issued by Water Resources) N/A (Parcel No.) N/A (Subdivision Name)

3. **WORK PERFORMED**
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. **PROPOSED USE**
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. **WELL TYPE**
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thickness
Original Construction Detail:				
Cement		0	52	52
Hole plug		52	401	349
Gravel pack		401	458	57
Hole plug		458	760	302
Cement		760	780	20
Hole plug		780	792	12
Gravel pack		792	845	53
Abandoned by pumping both tubes full of cement, from T.D. to surface.				
Quantities Used:				
1: Cement = 39.7cu.ft.				
2: Cement = 30cu.ft.				

RECEIVED 03 JAN 31 AM 10:5 STATE ENGINEERS OFFICE

Date started 1/16/2003, 19__
Date completed 1/16/2003, 19__

7. **WELL TEST DATA**
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. **WELL CONSTRUCTION**
Depth Drilled 845 Feet Depth Cased 838 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
15	Inches	0	Feet	37	Feet
8.25	Inches	37	Feet	845	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10.75	34.24	0.250	0	37
1: 2.375	3.65	0.154	+2	838
2: 2.375	3.65	0.154	+2	450

Perforations:
Type perforation Slotted
Size perforation 0.020"
From 1: 798 feet to 838 feet
From 2: 410 feet to 450 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 52'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From See Detail feet to feet

9. **WATER LEVEL**
Static water level 1: Dry 2: 444.2' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. **DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Lang Exploratory Drilling (Contractor)
Address P.O. Box 5279 (Contractor)
Elko, NV 89802-5279
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1716
Signed DAVID HAYES (By driller performing actual drilling on-site or contractor)
Date 1/29/03

USE ADDITIONAL SHEETS IF NECESSARY

B.S.L