

Log No. 88884  
Permit No. 087  
Basin 087

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 22649

1. OWNER K.G. Walters ADDRESS AT WELL LOCATION 8500 Mira Loma Blvd, Reno NV  
MAILING ADDRESS 10275 Loch Haven Dr. Santa Rosa, CA  
2. LOCATION N E 1/4 NW 1/4 Sec. 4 T 18 0 S R 20 E Washoe County  
PERMIT NO. DEW-28 022-220-04 Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE Temp Dewatering WELL TYPE  
 Domestic  Irrigation  Test  Cable  Rotary  RVC  
 Municipal/Industrial  Monitor  Stock  Air  Other Bucket Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Abandoned 18 wells.				
Pulled well casing				
Removed gravel pack down to 20'				
Poured Concrete Grout in hole to the top of ground.				

8. WELL CONSTRUCTION  
Depth Drilled 45' Feet Depth Cased 45' Feet  
HOLE DIAMETER (BIT SIZE)  
From 24" Inches To 42" Feet  
Inches Feet  
Inches Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8"	PVC	3/8 - 40	0	45'

Perforations:  
Type perforation  
Size perforation  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes,  No Seal Type:  
Depth of Seal 20'  Neat Cement  
 Cement Grout  
Placement Method:  Pumped  Poured  Concrete Grout

Gravel Packed:  Yes  No  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
Static water level 90' feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 8-17-02, 20  
Date completed 8-27-02, 20

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Griffith's Dewatering Contractor  
Address 536 E. Mainland St. Ontario, CA 91761 Contractor  
Nevada contractor's license number issued by the State Contractor's Board 0031246  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1985  
Signed [Signature] By driller performing actual drilling on site or contractor  
Date 8-27-02