

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 98941  
 Permit No. \_\_\_\_\_  
 Basin 105

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **50620**

1. OWNER Ed. Mahoney Const. ADDRESS AT WELL LOCATION 1294 Kingsbury Grade  
 MAILING ADDRESS Gardnerville, NV 89410 Gardnerville, NV. 89406

2. LOCATION NE 1/4 SE 1/4 Sec. 4 T 12N N/S R 19E E Douglas County  
 PERMIT NO. 1219-04-002-011 Kingsbury Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
DG and Granite Boulders	No	0	28	28
DG course	No	28	97	69
DG Granite Boulders	No	97	116	19
Hard Granite	No	116	257	141
DG with br. clay	No	257	291	34
Fractured Granite with fine sand in Fractures	YES	291	363	72
Frctured Granite with clay in fractures	NO	363	370	7

RECEIVED  
 02 DEC 19 AM 11:20  
 STATE ENGINEERS OFFICE

Date started 11/25/2002, 19  
 Date completed 12/8/2002, 19

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
30		2 hrs	

8. WELL CONSTRUCTION

Depth Drilled 370 Feet Depth Cased 370 Feet

HOLE DIAMETER (BIT SIZE)

From	To
10 5/8 Inches	0 Feet to 60 Feet
9 7/8 Inches	60 Feet to 370 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+2	370

Perforations:

Type perforation Factory Milled  
 Size perforation 3/16 X 3 6 Row

From	To
330 feet to	370 feet
feet to	feet
feet to	feet
feet to	feet
feet to	feet

Surface Seal:  Yes  No  
 Depth of Seal \_\_\_\_\_  
 Placement Method:  Pumped  Poured  
 Seal Type:  Neat Cement  Cement Grout  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 370 feet

9. WATER LEVEL

Static water level 160 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Eddco Exploration Inc. Contractor  
 Address 7780 Curry Rd. Contractor  
Fallon, NV. 89406  
 Nevada contractor's license number issued by the State Contractor's Board 27673A  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1586  
 Signed [Signature]  
 By driller performing actual drilling on-site or contractor  
 Date 12/17/2002