

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 50434

1. OWNER Joe & Mary Aranyos ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 2652 Wabash Circle 1335 American Flat Road
Sparks, Nevada 89434 Reno, Nevada 89506
 2. LOCATION SE 1/4 SE 1/4 Sec. 33 T. 22N N/S R. 19 E Washoe County _____
 PERMIT NO. 079-420-17 Red Rock Estates # 327
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	2	2
Brown sand		2	6	4
Brown sand with gravel some boulders		6	17	11
Brown sandy clays some gravels		17	70	53
Brown clays with decomposed granite sands		70	85	15
Soft zone		85	90	5
Brown sandy clays		90	170	80
Weathered granite with clay streaks		170	218	48
Weathered granite		218	297	79
Fracture granite (NO WATER)		297	305	8
Gray granite some weathered zones		305	360	55
Fracture rock (NO H2O)		360	366	6
Gray granite		366	379	13
Fracture granite	X	379	381	2
Gray granite		381	402	21
Fracture granite		402	421	19
Gray granite		421	424	3

8. WELL CONSTRUCTION
 Depth Drilled 424 Feet Depth Cased 424 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 Inches 0 Feet 50 Feet
8 5/8 Inches 50 Feet 424 Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	424

 Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 381 feet to 421 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 feet Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 424 feet

Date started December 3, 2002 20____
 Date completed December 6, 2002 20____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
10		

9. WATER LEVEL
 Static water level 335 feet below land surface
 Artesian flow _____ G.P.M. 10 P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510
 Nevada contractor's license number issued by the State Contractor's Board 0022549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date December 10, 2002

RECEIVED
 02 DEC 17 AM 10:28
 STATE ENGINEERS OFFICE