

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 39401

1. OWNER Carter Gold Mines ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS MC 66-50
Beowawe, NV.
 2. LOCATION SE 1/4 SW 1/4 Sec. 12 T. 27 N. 1347 E Lander County
 PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Sonic

6. MW 91 LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>mix - Sand silt clay</u> <u>lt brown</u> <u>soft / damp</u>		<u>0</u>	<u>3.5</u>	<u>3.5</u>
<u>fine - coarse sand</u> <u>w/ gravel up to 2"</u> <u>lt brown</u> <u>soft / damp</u>		<u>3.5</u>	<u>6</u>	<u>2.5</u>
<u>fine - coarse sand</u> <u>w/ gravel up to 1.5"</u> <u>soft / damp</u>		<u>6</u>	<u>10.5</u>	<u>4.5</u>
<u>fine sand silt</u> <u>w/ gravel up to 1"</u> <u>soft / damp</u>		<u>10.5</u>	<u>15</u>	<u>4.5</u>
<u>fine sand</u> <u>w/ gravel up to 3/4"</u> <u>soft / moist - wet</u>		<u>15</u>	<u>20</u>	<u>5</u>
<u>fine - med sand</u> <u>w/ small gravel</u> <u>soft / saturated</u>		<u>20</u>	<u>22</u>	<u>2</u>
<u>fine sand clay</u> <u>soft / saturated</u>		<u>22</u>	<u>41</u>	<u>9</u>

8. WELL CONSTRUCTION
 Depth Drilled 41 Feet Depth Cased 30 Feet
 HOLE DIAMETER (BIT SIZE)
 From 8.5 Inches To 0 Feet 41 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4.5</u>	<u>2.86</u>	<u>.337</u>	<u>30</u>	<u>+2.5</u>

Perforations:
 Type perforation Factory cut
 Size perforation 220
 From 2.5 feet to 15 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 14
 Placement Method: Pumped
 Poured
 Gravel Packed: Yes No
 From 30 feet to 14.5 feet

9. WATER LEVEL
 Static water level 17 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Warm F Quality _____

Date started 6-29 1998
 Date completed 6-29 1998

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw-Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
	<u>02:11:30</u>	<u>01:31:45</u>	

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Boast Longyear Contractor
 Address 7773 W. Seldon Ln
Peoria, AZ 85345
 Nevada contractor's license number issued by the State Contractor's Board 0010157
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M2071-T1
 Signed Wan Casar
 By driller performing actual drilling on site or contractor
 Date 7/22/98