

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24721

1. OWNER East Union Realty ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 9860 W. Pebble Rd Las Vegas NV 89124 ~~9824 W. Pebble Rd~~
 2. LOCATION SE 1/4 SW 1/4 Sec 18 T 22 N/S R 60 E Clark County
 PERMIT NO. 176-18-401-012 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Municipal/Industrial Irrigation Monitor Test Stock
 5. WELL TYPE
 Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Cemented Sand & Gravel</u>		<u>0</u>	<u>30</u>	<u>30</u>
<u>Clay & Gravel</u>		<u>30</u>	<u>145</u>	<u>115</u>
<u>Red Clay Stone</u>		<u>145</u>	<u>160</u>	<u>15</u>
<u>Cemented Soil</u>		<u>160</u>	<u>460</u>	<u>300</u>
<u>Red Sand Stone</u>	<input checked="" type="checkbox"/>	<u>460</u>	<u>560</u>	<u>100</u>
<u>Sand Stone - Clay Gravel</u>	<input checked="" type="checkbox"/>	<u>560</u>	<u>675</u>	<u>115</u>

8. WELL CONSTRUCTION
 Depth Drilled 675 Feet Depth Cased 660 Feet
 HOLE DIAMETER (BIT SIZE)
 From 11 Inches To 0 Feet 675 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 F480 P.V.C.</u>			<u>660</u>	<u>+1</u>

Perforations:
 Type perforation Saw
 Size perforation 1/2 x 12
 From 660 feet to 560 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50+
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 660 feet to 50 feet

DCNR/DWR
 RECEIVED
 APR 15 2003
 LAS VEGAS OFFICE

9. WATER LEVEL
 Static water level 465 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 60.5 °F Quality good

Date started 3-31-03, 19____
 Date completed 4-10-03, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30</u>		<u>148</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Redding Drilling Contractor
 Address 3855 Blue Diamond Rd #4 Las Vegas NV 89139 Contractor
 Nevada contractor's license number 38155 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1617
 Signed Floyd Mitchell
 By driller performing actual drilling on site or contractor
 Date 4-10-03