

COPIES TO
 - DIVISION OF WATER RESOURCES
 - CLIENT'S COPY
 - WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 89034
 Permit No. _____
 Basin 105

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 49414

1. OWNER RAY PLIMPTON
 MAILING ADDRESS GARDNERVILLE, NV 89410
 ADDRESS AT WELL LOCATION 212 MOUNTAIN REACH CT GARDNERVILLE, NV 89410

2. LOCATION SW 1/4 SW 1/4 Sec 3 T 12 N R 19 E DOUGLAS County

PERMIT NO. 1219-03-002-005

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
LARGE GRANITE BOULDERS		0	16	16
DG BOULDERS AND COBBLES		16	65	49
DG SANDS AND COBBLES		65	134	69
SANDSTONE GRANITE		134	189	55
BROWN CLAY SANDY		189	237	48
FRACTURED DG SAND		237	268	31
FRACTURED SOFT GRANITE ZONE	XXX	268	300	32

8. WELL CONSTRUCTION

Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

From	To
<u>10 5/8</u> Inches	<u>0</u> Feet <u>300</u> Feet
_____ Inches	_____ Feet _____ Feet
_____ Inches	_____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>300</u>

Perforations:

Type perforation FACTORY MILL SLOT
 Size perforation 3 X 3/32

From 280 feet to 300 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 300 feet

9. WATER LEVEL

Static water level 160' feet below land surface
 Artesian flow _____ G.P.M. 22 P.S.I.
 Water temperature COLD °F Quality GOOD

Date started 11/24, 20 02
 Date completed 11/28, 20 02

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name CAPITAL CITY WELL DRILLING
 (CONTRACTOR)
 Address 20 KIT KAT DRIVE
 (CONTRACTOR)
CARSON CITY, NV 89706
 Nevada contractor's license number issued by the State Contractor's Board 41775
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905

Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 11/29/02

7. WELL TEST DATE

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>22</u>	<u>60</u>	<u>3 HRS</u>

RECEIVED
 02 DEC 17 AM 10:07
 STATE ENGINEERS OFFICE