COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 89043
Permit No.
Basin 105

NOTICE OF INTENT NO. 49415

1. OWNER BLAIN MCGUIRE CONSTRUCTION
MAILING ADDRESS 2110 EASTLAKE BLVD
CARSON CITY, NV 89703

ADDRESS AT WELL LOCATION 998 EDNA DRIVE
GARDNERVILLE, NV 894510

2. LOCATION NE ¼ SW ¼ Sec 17 T 12 N R 20 E DOUGLAS County

PERMIT NO. (Issued by Water Resources) | Parcel No. 1220-17-101-003 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
HARDPAN CLAY		0	5	5
COURSE SANDS AND BROWN CLAY		5	16	9
COURSE GRAVELS		16	21	5
LARGE GRAVELS		21	45	24
LARGE GRAVELS		45	119	84
COURSE GRAVELS 1 INCH GRAVELS	XXX	119	140	21

RECEIVED
03 JAN -8 AM 11:07
STATE ENGINEERS OFFICE

Date started 12/11, 20 02
Date completed 12/13, 20 02

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	40	3 HRS

8. WELL CONSTRUCTION

Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 3/4 Inches	0 Feet	140 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	140

Perforations:
Type perforation FACTORY MILL SLOT
Size perforation 3 X 3/32
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 55' ☒ Neat Cement
Placement Method: ☒ Pumped ☐ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 100 feet to 140 feet

9. WATER LEVEL
Static water level 25 feet below land surface
Artesian flow G.P.M ~~30~~ P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 41775
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157
Signed Rick Crane
By driller performing actual drilling on site or contractor
Date 112/11/02

(Rev 3-91) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk, Inc. · Dallas, Texas · (214) 340-9429