COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 89049
Permit No.
Basin 105

NOTICE OF INTENT NO. 49439

1. OWNER DAN HICKEY CONSTRUCTION
MAILING ADDRESS 1456 FOOTHILLS RD
GARDNERVILLE , NV 89410

ADDRESS AT WELL LOCATION 197 TAYLOR CREEK RD
GARDNERVILLE , NV 89410

2. LOCATION SW ¼ SW ¼ Sec 3 T 12 N R 19 E DOUGLAS County

PERMIT NO. (Issued by Water Resources) | Parcel No. 1219-03-001-070 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
COURSE DG SANDS		0	6	6
DARK BROWN SANDS				
RUSTY BROWN DG		6	47	41
SANDS AND CLAY				
BROWN CLAY		47	110	63
SILTY GRAY SANDS		110	157	47
GRAY CLAY		157	160	3
FRACTURED DG	XXX	160	180	20
SANDS AND COBBLES				

Date started 12/1 , 20 02
Date completed 12/3 , 20 02

RECEIVED 03 JAN -8 AM 11:07 STATE ENGINEERS OFFICE

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25+	40	3 HRS

8. WELL CONSTRUCTION

Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 3/4 Inches	0 Feet	180 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	180

Perforations:
Type perforation MILL SLOT
Size perforation 3 X 3/32
From 160 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 100 ☒ Neat Cement
Placement Method: ☒ Pumped ☐ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 100 feet to 180 feet

9. WATER LEVEL
Static water level 55 feet below land surface
Artesian flow G.P.M 25+ P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY , NV 894706
Nevada contractor's license number issued by the State Contractor's Board 41775
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed [signature] By driller performing actual drilling on site or contractor
Date 12/08/02