MW2-5

WHITE--DIVISION OF WATER RESOURCES
CANARY--CLIENT'S COPY
PINK--WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
No. 89062
Permit No.
Basin 072

NOTICE OF INTENT NO. 43494

1. OWNER FLORIDA CANYON MINING, INC.
MAILING ADDRESS P.O. BOX 330
IMLAY, NV 89418

ADDRESS AT WELL LOCATION STANDARD MINE AREA

2. LOCATION NE ¼ NW ¼ Sec. 35 T 31 N N/S R 33 E PERSHING County
PERMIT NO. M/O 1229 A (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [X] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Alluvium		0	80	80
Argillite		80	600	520
Water Level: 142 feet below surface				

RECEIVED 02 AUG 22 AM 11:08 STATE ENGINEER'S OFFICE

DCNR/DWR RECEIVED MAY 05 2003 LAS VEGAS OFFICE

Date started July 18, 2002, 19
Date completed July 24, 2002, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 600 Feet Depth Cased 500 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
5 3/4 Inches	0 Feet	600 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2	PVC	Sch.80	+2	500

Perforations:
Type perforation Mill slot PVC
Size perforation .020
From 100 feet to 500 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100 feet to 500 feet

9. WATER LEVEL
Static water level 142 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name DELONG CONSTRUCTION, INC. (Contractor)
Address P.O. BOX 907 WINNEMUCCA, NV 89446 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 0002120C
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 01375
Signed (By driller performing actual drilling on site or contractor)
Date 8-2-02

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627