WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 89074
Permit No. 66906
Basin 164A

NOTICE OF INTENT NO. 24716

1. OWNER Sierra Ready Mix
MAILING ADDRESS 4150 Smiley Rd.
No. Las Vegas NV. 89031

ADDRESS AT WELL LOCATION Jean Nev.
4½ mi. So. of Prison

2. LOCATION NE ¼ NW ¼ Sec. 6 T. 26 N/S R. 60 E. Clark County
PERMIT NO. 66906 Issued by Water Resources
224-00-001-006 Parcel No.
Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand & Gravel		0	125	125
Cemented Gravel		125	175	50
Lime Stone		175	275	100
Brown Clay Gravel		275	295	20
Clay Stone + Clay		295	400	105
Lime Stone		400	480	80
Sand Stone	✓	480	540	60
Clay		540	560	20
Sand Stone	✓	560	660	100
Grey Shale		660	670	10
Sand Stone	✓	670	760	90
Blue Shale	✓	760	848	88
Lime Stone	✓	848	900	52

DCNR/DWR
RECEIVED
APR 15 2003
LAS VEGAS OFFICE

Date started 2-24-03, 19
Date completed 4-11-03, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
225		8 HRS.

8. WELL CONSTRUCTION
Depth Drilled 900 Feet Depth Cased 870 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12¼ Inches	0 Feet	900 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 IN.	P.V.C		870	+1
10 FT	16 IN	3/8		

Perforations:
Type perforation Factory
Size perforation .020
From 870 feet to 570 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50+
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 900 feet to 50 feet

9. WATER LEVEL
Static water level 245 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Redding Drilling (Contractor)
Address 3955 Blue Diamond Rd. #4 (Contractor)
Las Vegas NV 89139
Nevada contractor's license number issued by the State Contractor's Board 38155
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1617
Signed Floyd Mitchell (By driller performing actual drilling on site or contractor)
Date 4-11-03

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627