

OFFICE USE ONLY  
Log No. 89117  
Permit No. \_\_\_\_\_  
Basin. 179

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33065

1. OWNER Bob Ashcraft ADDRESS AT WELL LOCATION 172 Street  
MAILING ADDRESS 6313 Santa Cruz McGill Highway  
Las Vegas, NV 89108

2. LOCATION NW 1/4 SE 1/4 Sec. 25 T. 17 N/S&R 63 E White Pine County  
PERMIT NO. ASPN 10-290-52 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	5	5
Gravel & Clay		5	70	65
Clay Gravel & Sand		70	85	15
Water Bearing Gravel & Sand	x	85	105	20
Clay Gravel & Sand		105	115	10
Water Bearing Gravel & Sand	x	115	125	10
Gravel & Clay		125	135	10
Clay & Gravel		135	160	25

8. WELL CONSTRUCTION  
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)  
From \_\_\_\_\_ To \_\_\_\_\_  
10 Inches 0 Feet 160 Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	160

Perforations:  
Type perforation Factory  
Size perforation 1/8" x 2 1/2" 6 rows  
From 80 feet to 160 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No  
Depth of Seal 50 ft. Seal Type:  
 Neat Cement  
Placement Method:  Pumped  Poured  Concrete Grout  
Gravel Packed:  Yes  No  
From 50 feet to 160 feet

9. WATER LEVEL  
Static water level 90 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature cold °F Quality good

Date started February 10, 1998  
Date completed February 12, 1998

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>85</u>	<u>60</u>	<u>1</u>

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Christiansen Drilling, Inc. Contractor  
Address 557 Ely Avenue Contractor  
Ely, NV 89301  
Nevada contractor's license number 14790 issued by the State Contractor's Board.  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 641  
Signed Jerald D. Christiansen  
By driller performing actual drilling on site or contractor  
Date February 19, 1998

RECORDED  
98 FEB 24 AM 9:33  
STATE ENGINEERING OFFICE