

COPIES TO
 - DIVISION OF WATER RESOURCES
 - CLIENT'S COPY
 - WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
 WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 89131
 Permit No. _____
 Basin 105

PRINT OR TYPE ONLY

OWNER **BILL MERRILL CONSTRUCTION**
 MAILING ADDRESS **P.O. BOX 2262**
MINDEN, NV 89423

NOTICE OF INTENT NO. **49450**
1615 TERRY ANNE
MINDEN, NV 89423

SW SW 26 14 20 DOUGLAS
 1420-26-401-015

3. WORK PERFORMED <input checked="" type="checkbox"/> New Well <input type="checkbox"/> Replace <input type="checkbox"/> Recondition <input type="checkbox"/> Deepen <input type="checkbox"/> Abandon <input type="checkbox"/> Other		4. PROPOSED USE <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/> Municipal/Industrial <input type="checkbox"/> Monitor <input type="checkbox"/> Stock		5. WELL TYPE <input type="checkbox"/> Cable <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> RVC <input type="checkbox"/> Air <input type="checkbox"/> Other MUD	
--	--	--	--	--	--

6. LITHOLOGIC LOG				
Material	From	To	Thick-ness	
BLOW SANDS	0	4	4	
COURSE DG SANDS	4	86	82	
BROWN CLAY	82	169	87	
FINE SILTY SANDS	169	238	69	
DG SANDS	238	260	22	
GRAYISH BROWN CLAY	260	290	30	
COURSE DG SANDS	XXX	290	340	50

8. Depth Drilled 340 Feet		Depth Cased 340 Feet	
From 10 3/4 Inches		To 0 Feet 340 Feet	
Inches		Feet	
Inches		Feet	
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)
6 5/8	13.03	.188	0
			340

Type perforation	FACTORY MILL SLOT
Size perforation	3 X 3/32
From 320 feet to 340 feet	
From _____ feet to _____ feet	
From _____ feet to _____ feet	
From _____ feet to _____ feet	

Surface Seal: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Seal Type:
Depth of Seal 60	<input checked="" type="checkbox"/> Neat Cement
Placement Method: <input type="checkbox"/> Pumped <input type="checkbox"/> Cement Grout	<input type="checkbox"/> Concrete Grout
<input checked="" type="checkbox"/> Poured	
Gravel Packed: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
From 60 feet to 340 feet	

9. Static water level 180 feet below land surface
Artesian flow _____ G.P.M. 20 P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION	
This well was drilled under my supervision and the report is true to the best of my knowledge.	
Name	CAPITAL CITY WELL DRILLING INC.

Date started	2/18, 20 03
Date completed	2/21, 20 03

7. WELL TEST DATE			
TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	20	70	3 HRS

Address	20 KIT KAT DRIVE
	CARSON CITY, NV 89706
Nevada contractor's license number issued by the	41775
Nevada driller's license number issued by the Division of Water Resources, the	2157
Signed	<i>Rick Crane</i>
	By driller performing actual drilling on site or contractor
Date	2/28/03