

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 47935

1. OWNER Larry Beaman ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 18650 Cold Springs \_\_\_\_\_  
Dr. Reno NV 89506 \_\_\_\_\_  
 2. LOCATION NE 1/4 NW 1/4 Sec. 20 T. 21 S. 18 E. Washoe County \_\_\_\_\_  
 PERMIT NO. 087-045-24 Parcel No. \_\_\_\_\_  
 Issued by Water Resources \_\_\_\_\_ Subdivision Name Cold Springs

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Top Soil</u>		<u>0</u>	<u>5</u>	<u>5</u>
<u>Clay &amp; gravel</u>		<u>5</u>	<u>8</u>	<u>3</u>
<u>Clay</u>		<u>8</u>	<u>78</u>	<u>70</u>
<u>Sandy Red clay</u>		<u>78</u>	<u>101</u>	<u>23</u>
<u>Clay</u>		<u>101</u>	<u>122</u>	<u>21</u>
<u>Sand &amp; Clay layers</u>	<u>x</u>	<u>122</u>	<u>160</u>	<u>38</u>

8. WELL CONSTRUCTION  
 Depth Drilled 160 Feet Depth Cased 160 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
11 Inches 0 Feet 160 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.9</u>	<u>.188</u>	<u>2+</u>	<u>160</u>

Perforations:  
 Type perforation Saw slot  
 Size perforation 3/16  
 From 160 feet to 120 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 160 feet

9. WATER LEVEL  
 Static water level 47 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 2/5/03  
 Date completed 3/10/03

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20</u>	<u>160</u>	<u>8</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Olenki Drilling & Pump Co Contractor  
 Address 15045 Red Rock Rd Contractor  
RENO NV 89506  
 Nevada contractor's license number 50343 issued by the State Contractor's Board.  
 Nevada driller's license number issued by the Division of Water Resources, the on site driller 1656  
 Signed John F. Olenki  
 By driller performing actual drilling on site or contractor  
 Date 3/17/03