WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 89151
Permit No.
Basin 105

NOTICE OF INTENT NO. 47866

OWNER Randy Roser
MAILING ADDRESS 1191 Rabe Way
Carson City, NV 89701

ADDRESS AT WELL LOCATION 1191 Rabe Way

2. LOCATION SW 1/4 SE 1/4 Sec. 5 T 14N N/S R 20E E Carson County
PERMIT NO. Issued by Water Resources
09-311-36 Parcel No.
Subdivision Name

3. WORK PERFORMED
[ ] New Well [ ] Replace [ ] Recondition
[X] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fine and coarse sand	xx	74	120	46
We deepened this 8 5/8" domestic water well and cased with 6 5/8" casing.				

RECEIVED
03 FEB 13 AM 11:20
STATE ENGINEER'S OFFICE

Date started 2/4/2003, 19__
Date completed 2/4/2003, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [X] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air	40		3 hrs
Pump	28	36	24 hrs

8. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
7 7/8"	Inches	74 Feet	120 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	40	120

Perforations:
Type perforation Factory
Size perforation 3/32 x 3"
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [ ] Yes [X] No
Depth of Seal
Placement Method: [ ] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 14 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. Contractor
Address 1600 Mt. Rose Hwy Contractor
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719
Signed R Bundy
By driller performing actual drilling on-site or contractor
Date 2/8/03

USE ADDITIONAL SHEETS IF NECESSARY