



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 50908

1. OWNER Marido ADDRESS AT WELL LOCATION 1682 Hyde St.
 MAILING ADDRESS 1682 Hyde St MINORNA NV 89423
MINORNA NV 89423
 2. LOCATION NE 1/4 NW 1/4 Sec 2 T 13 R 20 E Douglas County
 PERMIT NO. 1320.02.001015 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other plug
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Plugging procedure =				
Dig mud pit set up gear				
REAM out to 420'				
pumped over 7500 gallons of mud in ground to clean 100' of hole already drilled. OK to				
grout @ 420' to 318' by TOM LAUGHER.				
grout hole from 420' to above bottom of liner. circulate from 315' to clean out grout from perfs. Tag grout @ 323' Air lift develop.				
Date started <u>1-27-03</u> 19				
Date completed <u>1-31-03</u> 19				

8. WELL CONSTRUCTION
 Depth Drilled 500 Feet Depth Cased 318 Feet
 HOLE DIAMETER (BIT SIZE) reamed 6" size
 From 6" Inches To size Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
 Type perforation _____
 Size perforation _____
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 323 - 420 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 148 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COOL °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Sierra Nv Drilling + Pump LLC Contractor
 Address 3540 Green Acres Dr Contractor
Carson City Nv
 Nevada contractor's license number 52078
 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1902
 Signed John S. Smith
 By driller performing actual drilling on site or contractor
 Date 2-19-03

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>25-30</u>		<u>2</u>