

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 415745

1. OWNER Jim Gordon ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS PO Box 116 Let 7 Valmy NV  
Valmy NV 89438  
 2. LOCATION NE 1/4 SW 1/4 Sec. 27 T. 34 N/S R. 43 E Humboldt County  
 PERMIT NO. \_\_\_\_\_ Issued by Water Resources \_\_\_\_\_ Parcel No. 007-571-07 Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>cleaned hole to 150'</u>				
<u>Raw Perforator 50' to 130'</u>				
<u>2 passes at 90°</u>				
<u>Raw 2 3/8 trimmy line to bottom</u>				
<u>Pumped Super Plug 41 gals water per 50lb sack to 20'</u>				
<u>Cemented to surface</u>				

8. WELL CONSTRUCTION  
 Depth Drilled 150 Feet Depth Cased 150 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 6 7/8 inches To 0 Feet 150 Feet  
 \_\_\_\_\_ inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

 Perforations:  
 Type perforation \_\_\_\_\_  
 Size perforation \_\_\_\_\_  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 20'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 12-4 2002  
 Date completed 12-9 2002

7. WELL TEST DATA

TEST METHOD:  Bailor  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL  
 Static water level 0 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name HARD ROCK Exploration Contractor  
 Address 1000 BARRINGTON AVE Contractor  
EIKO NV 89801  
 Nevada contractor's license number issued by the State Contractor's Board 0046949  
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 1670  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 12-16-02