

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 41547

1. OWNER Gayle Bill Morrison ADDRESS AT WELL LOCATION Lot 17 Valmy NV.
 MAILING ADDRESS P.O. Box 100 Valmy NV 89438
 2. LOCATION SE 1/4 SW 1/4 Sec 27 T 34 N/S R 43 E Humboldt County
 PERMIT NO. 007-571-17 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>cleaned hole to 175'</u>				
<u>RAW perforator 55' to 155'</u>				
<u>2 cuts 90"</u>				
<u>RAW 2 3/8 Trimmey line to bottom</u>				
<u>pumped Super Plug to 20'</u>				
<u>Cemented to surface</u>				
<u>41 Gallons water to 5015 Super Plug</u>				
<u>13 1/2 Solids</u>				

8. WELL CONSTRUCTION

Depth Drilled _____ Feet Depth Cased _____ Feet

HOLE DIAMETER (BIT SIZE)

From		To	
Inches	Feet	Feet	Inches
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
_____	_____	_____	_____	_____
_____	_____	_____	_____	_____

Perforations:

Type perforation _____
 Size perforation _____

From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 20' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From _____ feet to _____ feet

Date started 12-2-002
 Date completed 12-2-002

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
_____	_____	_____
_____	_____	_____
_____	_____	_____

9. WATER LEVEL

Static water level 161 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name HARD ROCK Exploration Contractor
 Address 1000 BARRINGTON AVE Contractor
ELKO NV 89801
 Nevada contractor's license number issued by the State Contractor's Board 0046949
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 1670
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 12-10-02