

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
 WELL DRILLER'S REPORT

office use only
 Log No. 97205
 Permit No. 104
 Basin 104
 NOTICE OF INTENT NO 48479
 Topsy + 395

1. OWNER **Robert Enz Const**
 MAILING ADDRESS **PO BOX 1766**
Carson City

ADDRESS AT WELL LOCATION

2. Location **SW 1/4 NE 1/4 Sec 6 T 14N R 20E**
 PERMIT NO. **PARCEL NO. 13-031-04**

Douglas County

SUBDIVISION NAME

3. WORK PERFORMED | 4. PROPOSED USE | 5. WELL TYPE

New Well	Replace	Recondition	<input checked="" type="checkbox"/> Domestic	Irrigation	Test	Cable	Rotary	RVC
Deepen	<input checked="" type="checkbox"/> Abandon	Other	Municipal/Industrial	Monitor	Stock	Air	Other	Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Bailed well from 172' to 200'				0
Perfed from 60' to 200'.				0
We hit cement at 59'.				0
Installed termie to 200' & pumped 4.5 yds of neat cement.				0

8. WELL CONSTRUCTION

Depth Drilled **200 feet** Depth Cased **200 feet**
 HOLE DIAMETER (BIT SIZE)

	From	To
inches	0	feet
inches		feet
inches		feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.94	188	+1 1/2	200

Perforations::

Type Perforation	Factory
Size perforation	3/32 x 3"
From	60 feet to 200 feet
From	feet to feet
From	feet to feet
From	feet to feet
From	feet to feet

Surface Seal YES No Seal Type:
 Depth of Seal **200 feet** Neat Cement
 Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From feet to feet

RECEIVED
 03 MAR 19 AM 11:21
 STATE ENGINEERS OFFICE

Date started **1-13 -02**
 Date completed **1-14 -02**

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	x	Air Lift
G.P.M.	Draw Down (Feet Below Static)			Time (hours)

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **McKay Drilling, Inc.**
2290 Pioneer Drive
Reno, NV 89509

NV Contractors No. **14170**
 NV Driller's Lic (on site) **1261T**

Signed Steve McKay
 By driller performing actual drilling on site or contractor

Date **1-15 -02**