WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

**Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340**

OFFICE USE ONLY
Log No. 89242
Permit No.
Basin Ø92-B

NOTICE OF INTENT NO. 47101

1. OWNER ART PEKAROVICH
MAILING ADDRESS P.O. Box 33459
Reno, Nevada 89533

ADDRESS AT WELL LOCATION 8650 Wise Avenue
Reno, Nevada 89506

2. LOCATION SW ¼ NW ¼ Sec. 4 T. 20N N/S R. 19 E. Washoe County
PERMIT NO. Letter 9-16-02 (Issued by Water Resources) 086-416-04 (Parcel No.) Lemmon Valley (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Top soil | | 0 | 1 | 1 |
| Brown sandy clay | | 1 | 13 | 12 |
| Cemented gravel | | 13 | 16 | 3 |
| Brown sandy clay | | 16 | 60 | 44 |
| Soft brown sands (2¼GPM) | X | 60 | 66 | 6 |
| Brown sandy clays | | 66 | 71 | 5 |
| Soft brown sands (2½GPM) | X | 71 | 73 | 2 |
| Brown sandy clays | | 73 | 101 | 28 |
| Decomposed granite | | 101 | 130 | 29 |
| Weathered granite | | 130 | 139 | 9 |
| Fracture | X | 139 | 141 | 2 |
| Weathered granite | | 141 | 164 | 23 |
| Fracture | X | 164 | 166 | 2 |
| Weathered granite | | 166 | 188 | 22 |
| Fracture | X | 188 | 190 | 2 |
| Weathered granite | | 190 | 198 | 8 |

RECEIVED 03 APR 1 AM 11:05 STATE ENGINEERS OFFICE

Date started March 28, 2003, 20
Date complated April 1, 2003, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|---|
| 18+ | | | |

8. WELL CONSTRUCTION
Depth Drilled 198 Feet Depth Cased 198 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 10 Inches | | 0 Feet | 50 Feet |
| 8 5/8 Inches | | 50 Feet | 198 Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | | .188 | 0 | 198 |

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 133 feet to 193 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 feet
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 198 feet

9. WATER LEVEL
Static water level 62 feet below land surface
Artesian flow 18+ G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510
Nevada contractor's license number issued by the State Contractor's Board 0022549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed [signature] (By driller performing actual drilling on site or contractor)
Date April 2, 2003

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627