

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 44405

1. OWNER Coyote Creek Ranch ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS Wendover Lake 13400 highway 400 2 mile east of I 80 mile marker
Winnemucca NV 89418 210 Buens Brothers Exit
 2. LOCATION NW ¼ NE ¼ Sec 27 T. 33 N/S R. 35 E # Peashing County _____
 PERMIT NO. Domestic 08-100-04 Parcel No. N/A Subdivision Name _____
Issued by Water Resources

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Topsoil		0	2	2
white 3/8 Rock		2	40	38
shale blue + white		40	70	30
Rock 3/8		70	80	10
Sand		80	100	20
Clay		100	140	40
Yellow shale		140	160	20
Chipped Gray Rock		160	255	95
Black Shale		255	260	5
Brown chipped Rock		260	300	40
Fine shale		300	300	0
Gray shale/sand	3-5	320	330	10
Shale		330	380	50
Sand		380	390	10
Black shale		390	420	30
Hard Rock		420	460	40
460 Sand + Clay	3-5	460	500	40
Hard Blue Clay		500	506	6

8. WELL CONSTRUCTION
 Depth Drilled 506 Feet Depth Cased 506 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 5/8 Inches 0 Feet 506 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>10</u>	<u>1.58</u>	<u>+1</u>	<u>506</u>

Perforations:
 Type perforation Factory cut
 Size perforation 3/32 x 1/4
 From 506 feet to 466 feet
 From 380 feet to 320 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 506 feet

9. WATER LEVEL
 Static water level 134 feet below land surface
 Artesian flow N/A G.P.M. N/A P.S.I.
 Water temperature 60.1 °F Quality Fair

Date started March 27 2003
 Date completed March 31 2003

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>8-10</u>	<u>5</u>	<u>5</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name FRED ANDERSON Drilling, Inc. Contractor
 Address 10760 Grass Valley Road Contractor
Winnemucca, NV 89445
 Nevada contractor's license number issued by the State Contractor's Board 02467
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 01375
 Signed [Signature]
 Date April 2 2003

RECEIVED
 APR 16 AM 10:56
 STATE ENGINEERS OFFICE