

Job #: 41292
 WHITE-DIVISION OF WATER RESOURCES
 CANARY-CLIENT'S COPY
 PINK-WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Log No. 87258
 Permit No.
 Basin 105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22727

Douglas County Sewer

1. OWNER Improvement Dist. ADDRESS AT WELL LOCATION
 MAILING ADDRESS P.O. Box 578 2120 Stockyard Rd.
 Zephyr Cove, NV 89448 Minden, NV

2. LOCATION SW 1/4 SE 1/4 Sec. 18 T. 13 N/S R. 21 E MDB & M County
 PERMIT NO. D0005 23-010-68
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
MW 20				
PERFORATE CASING 1/4" x 1" x 16 ROW/FT BETWEEN 50-66'				
TREMIE GROUT 0-185 CEMENT GROUT				
Remove upper 5' of casing; MUSTROOM CAP & BACKFILL w/ NATIVE SOIL				

8. WELL CONSTRUCTION
 Depth Drilled 185 Feet Depth Cased 185 Feet

HOLE DIAMETER (BIT SIZE)

From	To
10-3/4 Inches	50 Feet
6-5/8 Inches	125 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10-3/4		.250	0	50
6-5/8		.250	50	162
5		.250	180	185

Perforations:
 Type perforation Screen
 Size perforation .20

From	feet to	feet
159	180	

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 68.5 feet below land surface
 Artesian flow NO G.P.M. P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Gene S. Golar for Beylik Drilling Contractor
 Address 555 S. Harbor Blvd. Contractor
 La Habra, CA 90631-6124
 Nevada contractor's license number 0007055A issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2174
 Signed Gene Golar By driller performing actual drilling on site or contractor
 Date 8-6-02

Date started 7/17/02
 Date completed 7/19/02

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	15		2.5

RECEIVED
 30 JAN 30 AM 10:56
 STATE ENGINEERS OFFICE