

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

PRINT OR TYPE ONLY
 NOT WRITE ON BACK

NOTICE OF INTENT NO 22030

1. OWNER Amerco Real Estate / U-Haul ADDRESS AT WELL LOCATION 5316 Boulder Highway
 MAILING ADDRESS 2727 N. Central Avenue, Suite 500 Las Vegas NV 89122
Phoenix AZ 85004

2. LOCATION NE 1/4 SW 1/4 Sec 21 T 21S N/S R 62 E County Clark

PERMIT NO 161-21-301-002 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Concrete		0	3"	3"
Tan sand with gravel		3"	11.5'	11' 3"
Tan sand; trace gravel		11.5'	16.0'	4.5'
Brown silty sand; tr. clay		16.0'	26.0'	10.0'
Gravel; some sand		26.0'	29.0'	3.0'
[Foam obscured nature of cuttings]		29.0'	45.0'	16.0'

8. WELL CONSTRUCTION

Depth Drilled 45 Feet Depth Cased 45 Feet

HOLE DIAMETER (BIT SIZE)

Inches	Feet	To	Feet
<u>6</u>	<u>0</u>	<u>45</u>	<u>45</u>

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2.375</u>		<u>0.308</u>	<u>0</u>	<u>45</u>

Perforations:

Type perforation Factory slot PVC
 Size perforation 0.020

From 15 feet to 45 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 6'

Placement Method Pumped Poured

Gravel Packed: Yes No
 From 12 feet to 45 feet

9. WATER LEVEL

Static water level 27 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATE

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Converse Consultants Contractor
 Address 731 Pilot Road, Suite H, Las Vegas NV 89119 Contractor

Nevada contractor's license number
 Issued by the State Contractor's Board 48947
 Nevada driller's license number issued by the
 Division of Water Resources, the on-site driller M 1589

Signed Ronald J. [Signature]
 By driller performing actual drilling on-site or contractor
 Date 5/15/03

7. WELL TEST DATA

TEST METHOD Bailer Pumped Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

Date started January 16, 2003
 Date completed January 16, 2003